



® *Light Engineered Displays, Inc.*

Graphic Annunciators \* Water Leak Detection  
Fireman's Smoke Control Panels \* ARA Systems

109 Portwatch Way Wilmington, N.C. 28412 Phone: (800) 251-2512 Fax: (800) 251-9878  
Internet: www.ledinc.com Email: sales@ledinc.com



## **General Description**

The Status Panel features red letters on a white background. The slim 2-1/2" deep box is painted white and is designed for surface mounting.

The message is bonded to a white acrylic sheet. The sign slides into place and is secured by a removable slide access panel. The lamps are located behind the message and is easily replaced.

The SP-1 is designed to accommodate a wide variety of applications. It is available for use with 12, 24 and 115 volt power.

## **Typical Messages**

DO NOT ENTER - FIRE SUPPRESSION SYSTEM HAS DISCHARGED IN AREA  
PLEASE EXIT ROOM - FIRE SUPPRESSION SYSTEM IS IN PRE-CHARGE CONDITION  
DO NOT USE ELEVATOR WHEN LIT - USE STAIRS  
EXIT

NOTE: Custom messages are available upon request. Please consult the factory for details.



# LIGHTED STATUS PANELS

## Enclosure Specifications

The SP-1 is constructed of 1/16" steel with a rust-resistant white industrial enamel finish. Access to the lamps is through a removable side panel. The standard message is available in a solid red on a white translucent slide-in panel. Other colors and styles are available. The sign is designed to be mounted on a wall over or adjacent to the door. Mounting holes are provided for this purpose. The **SP-1** model contains one message; the **SP-2** model displays two messages.

## Electrical Specifications

- **SP-1/115v** For 115 VAC Operation - Uses 2 20 watt incandescent lamps.
- **SP-1/12v** For 12 VDC Operation - Uses 4 12v incandescent lamps (250ma.)
- **SP-1/24v** For 24 VDC Operation - Uses 4 24v incandescent lamps (250ma.)
- **SP-1/Strobe** Specify 12 or 24 VDC Operation - Uses 1 strobe assembly (180ma.)

*When using the 24 volt models on a supervised signal circuit, a 1N4002 diode must be installed.*

