





A Division of:  
Light Engineered Displays, Inc.  
109 Portwatch Way  
Wilmington, N.C. 28412  
Phone: (800) 251-2512  
Fax: (800) 251-9878  
Internet: www.ledinc.com  
Email: sales@ledinc.com

### WD-SD/12 or WD-SD/24 Typical Wiring to WD-Series Control Panel



NOTE: The WD-SD 12 or 24v Spot Detector is also compatible with all 12 or 24 vdc alarm systems.  
To supervise the power connections, use a normally energized relay at the end of the line, and put the EOL resistor in series with the closed contact.

### WD-SD 0v Typical Wiring to WD-Series Control Panel



NOTE: The WD-SD 0v Spot Detector is compatible ONLY with AquaALERT Leak Detection Systems.  
The sensor cable and wiring is full supervised by the AquaALERT EM-1 or EM-4 control card of the WD-Series system.  
For specific applications, please consult the factory.